

#### **ENGINE PERFORMANCE CURVE**

Basic Engine Model: KTA38-G5

Curve Number: FR-6140

Page No.

Engine Critical Parts List:

Date:

**CPL: 1543** 

03JAN 04


Displacement : **37.8** litre (**2300** in<sup>3</sup>) Bore : **159** mm (**6.25** in.) Stroke : **159** mm (**6.25** in.)

No. of Cylinders: 12 Aspiration: Turbocharged and Aftercooled

Engine Speed	Standby Power		Standby Power Prime Power		Continuous Power	
RPM	kWm	ВНР	kWm	ВНР	kWm	ВНР
1500	970	1300	880	1180	656	880
1800						

# **Engine Performance Data @ 1500 RPM**

OUTPUT POWER			FUEL CONSUMPTION			
%	kWm	ВНР	kg/ kWm∙h	lb/ BHP∙h	litre/ hour	U.S. Gal/ hour
STANDBY POWER						
100	970	1300	0.200	0.329	228	60.3
PRIME POWER						
100	880	1180	0.202	0.332	209	55.1
75	660	885	0.207	0.341	161	42.5
50	440	590	0.218	0.360	113	29.9
25	220	295	0.251	0.416	65	17.3
CONTINUOUS POWER						
100	656	880	0.204	0.336	158	41.7
						•



# **Engine Performance Data @ 1800 RPM**

Not Available at 1800 RPM

Not Available at 1800 RPM

**CONVERSIONS:** 

(Litres = U.S. Gal x 3.785)

 $(kWm = BHP \times 0.746)$ 

(U.S. Gal = Litres x 0.2642)

(BHP = Engine kWm x 1.34)

Data shown above represent gross engine performance capabilities obtained and corrected in accordance with ISO-3046 conditions of 100 kPa (29.53 in Hg) barometric pressure [110 m (361 ft) altitude], 25 °C (77 °F) air inlet temperature, and relative humidity of 30% with No. 2 diesel or a fuel corresponding to ASTM D2. See reverse side for application rating guidelines.

The fuel consumption data is based on No. 2 diesel fuel weight at 0.85 kg/litre (7.1 lbs/U.S. gal).

Power output curves are based on the engine operating with fuel system, water pump and lubricating oil pump; not included are battery charging alternator, fan, optional equipment and driven components.

**TECHNICAL DATA DEPT.** 

**CERTIFIED WITHIN 5%** 

**CHIEF ENGINEER** 

# POWER RATING APPLICATION GUIDELINES FOR GENERATOR DRIVE ENGINES

These guidelines have been formulated to ensure proper application of generator drive engines in A.C. generator set installations. Generator drive engines are not designed for and shall not be used in variable speed D.C. generator set applications.

STANDBY POWER RATING is applicable for supplying emergency power for the duration of the utility power outage. No overload capability is available for this rating. Under no condition is an engine allowed to operate in parallel with the public utility at the Standby Power rating.

This rating should be applied where reliable utility power is available. A standby rated engine should be sized for a maximum of an 80% average load factor and 200 hours of operation per year. This includes less than 25 hours per year at the Standby Power rating. Standby ratings should never be applied except in true emergency power outages. Negotiated power outages contracted with a utility company are not considered an emergency.

CONTINUOUS POWER RATING is applicable for supplying utility power at a constant 100% load for an unlimited number of hours per year. No overload capability is available for this rating.

PRIME POWER RATING is applicable for supplying electric power in lieu of commercially purchased power. Prime Power applications must be in the form of one of the following two categories:

## **UNLIMITED TIME RUNNING PRIME POWER**

Prime Power is available for an unlimited number of hours per year in a variable load application. Variable load should not exceed a 70% average of the Prime Power rating during any operating period of 250 hours.

The total operating time at 100% Prime Power shall not exceed 500 hours per year.

A 10% overload capability is available for a period of 1 hour within a 12 hour period of operation. Total operating time at the 10% overload power shall not exceed 25 hours per year.

#### **LIMITED TIME RUNNING PRIME POWER**

Prime Power is available for a limited number of hours in a non-variable load application. It is intended for use in situations where power outages are contracted, such as in utility power curtailment. Engines may be operated in parallel to the public utility up to 750 hours per year at power levels never to exceed the Prime Power rating. The customer should be aware, however, that the life of any engine will be reduced by this constant high load operation. Any operation exceeding 750 hours per year at the Prime Power rating should use the Continuous Power rating.

# Reference Standards:

BS-5514 and DIN-6271 standards are based on ISO-3046.

## **Operation At Elevated Temperature And Altitude:**

The engine may be operated at:

1500 RPM up to 5,000 ft. (1525 m) and  $104^{\circ}$  F ( $40^{\circ}$  C) without power deration.

For sustained operation above these conditions, derate by 4% per 1,000 ft (300 m), and 1% per 10° F (2% per 11° C).

# **Engine Data Sheet**

DATA SHEET: DS-4891-A
DATE: 03JAN04
PERFORMANCE CURVE: FR-6140 **ENGINE MODEL: KTA38-G5 CONFIGURATION NUMBER**: D233031DX02

INSTALLATION DIAGRAM

• Fan to Flywheel : 3383897

• Heat Exchanger Cooled :

<u>CPL NUMBER</u>
• Engine Critical Parts List : 1543

Aspiration	— in x in (mm x mm)	Turbocharged a 6.25 x 6.25 (159	
Displacement  Compression Ratio	` _ /	0.70 x 0.70 t 109	
Compression Ratio			X 159)
·	, ,	2300 (37.8)	
De Maiela		13.9 : 1	
Dry Weight			
Fan to Flywheel Engine	— lb (kg)	9482	(4300)
Heat Exchanger Cooled Engine	— lb (kg)	9923	(4500)
Wet Weight			
Fan to Flywheel Engine	— lb (kg)	10002	(4536)
Heat Exchanger Cooled Engine	— lb (kg)	10602	(4808)
Moment of Inertia of Rotating Components			
with FW 6001 Flywheel	- lb <sub>m</sub> • ft <sup>2</sup> (kg • m <sup>2</sup> )	248	(10.4)
• with FW 6011 Flywheel		493	(20.8)
Center of Gravity from Rear Face of Flywheel Housing (FH 6024)		38.6	(980)
Center of Gravity Above Crankshaft Centerline		11.0	(279)
Maximum Static Loading at Rear Main Bearing	' '	2000	(908)
NGINE MOUNTING			
Maximum Bending Moment at Rear Face of Block	— lb • ft (N • m)	4500	(6100)
XHAUST SYSTEM			
Maximum Back Pressure	in 11a /man 11a)	2	(70)
Waximum Back Pressure	— in ng (mm ng)	3	(76)
IR INDUCTION SYSTEM			
Maximum Intake Air Restriction			
with Dirty Filter Element		25	(635)
with Normal Duty Air Cleaner and Clean Filter Element	— in $H_2O$ (mm $H_2O$ )	10	(254)
with Heavy Duty Air Cleaner and Clean Filter Element	— in $H_2O$ (mm $H_2O$ )	15	(381)
OOLING SYSTEM			
Coolant Capacity — Engine Only	— US gal (liter)	32.7	(124)
— with HX 6076 Heat Exchanger		52.7	(199)
	3 ( 12 )		( /
Maximum Coolant Friction Head External to Engine — 1800 rpm		N/A	N/A
— 1500 rpm		7	(48)
Maximum Static Head of Coolant Above Engine Crank Centerline	— ft (m)	60	(18.3)
Standard Thermostat (Modulating) Range	— °F (°C)	180 - 200	(82 - 93)
Minimum Pressure Cap	— psi (kPa)	10	(69)
Maximum Top Tank Temperature for Standby / Prime Power		220 / 212	(104 / 100)
Minimum Raw Water Flow @ 90°F to HX 6076 Heat Exchanger —	- US gpm (liter / min)	108	(409)
Maximum Raw Water Inlet Pressure at HX 6076 Heat Exchanger	— psi (kPa)	50	(345)
UBRICATION SYSTEM			
Oil Pressure @ Idle Speed	— psi (kPa)	20	(138)
@ Governed Speed		45 - 65	(310 - 448)
Maximum Oil Temperature	· · · · · · · · · · · · · · · · · · ·	250	(121)
Oil Capacity with OP 6023 Oil Pan : High - Low		30 - 23	(114 - 87)
Total System Capacity (Including Bypass Filter)		35.7	(135)
Total Oyotom Oupdoity (moldaling Dypado I litel/		55.7	30°
Angularity of OP 6023 Oil Pan — Front Down  — Front Up			30°

#### **FUEL SYSTEM**

Type Injection System	Direct Injection	Cummins PT
Maximum Restriction at PT Fuel Injection Pump — with Clean Fuel Filter — in Hg (mm Hg)	4.0	(102)
— with Dirty Fuel Filter— in Hg (mm Hg)	8.0	(203)
Maximum Allowable Head on Injector Return Line (Consisting of Friction Head and Static Head)	6.5	(165)
Maximum Fuel Flow to Injection Pump	113	(428)
ELECTRICAL SYSTEM		
Cranking Motor (Heavy Duty, Positive Engagement)	24	
Battery Charging System, Negative Ground — ampere	35	
Maximum Allowable Resistance of Cranking Circuit — ohm	0.002	
Minimum Recommended Battery Capacity		
• Cold Soak @ 50 °F (10 °C) and Above	1200	
• Cold Soak @ 32 °F to 50 °F (0 °C to 10 °C)	1280	
• Cold Soak @ 0 °F to 32 °F (-18 °C to 0 °C)	1800	

## PERFORMANCE DATA

All data is based on:

- Engine operating with fuel system, water pump, lubricating oil pump, air cleaner and exhaust silencer; not included are battery charging alternator, fan, and optional driven components.
- Engine operating with fuel corresponding to grade No. 2-D per ASTM D975.
- ISO 3046, Part 1, Standard Reference Conditions of:

Barometric Pressure : 100 kPa (29.53 in Hg) Air Temperature : 25 °C (77 °F) Altitude : 110 m (361 ft) Relative Humidity : 30%

Governed Engine Speed	— rpm
Engine Idle Speed	— rpm
Gross Engine Power Output	BHP (kW <sub>m</sub> )
Brake Mean Effective Pressure	psi (kPa)
Piston Speed	ft / min (m / s)
Friction Horsepower	— HP (kW <sub>m</sub> )
Engine Water Flow at Stated Friction F	lead External to Engine:
4 psi Friction Head	— US gpm (liter / s)
Maximum Friction Head	— US gpm (liter / s)

Engine Data with Dry Type Exhaust Manifold					
Intake Air Flow	cfm (liter / s)				
Exhaust Gas Temperature					
Exhaust Gas Flow	cfm (liter / s)				
Air to Fuel Ratio	— air : fuel				
Radiated Heat to Ambient	— BTU / min (kW <sub>m</sub> )				
Heat Rejection to Coolant	— BTU / min (kW <sub>m</sub> )				
Heat Rejection to Exhaust	— BTU / min (kW <sub>m</sub> )				

STANDBY			PRIME	POWER		
60 hz	50 hz		60 hz	50	) hz	
Not Applicable for 60 Hz Operation		(1213) (513) (594) (590)	Not Applicable for 60 Hz Operation	725 1180 271 1562 115 310 280 2415 930 6465	(19.6) (140) (140) (140) (149) (3051) (15) (539) (544)	

N.A. - Data is Not AvailableN/A - Not Applicable to this EngineTBD - To Be Determined

ENGINE MODEL: KTA38-G5
DATA SHEET: DS-4891-A
DATE: 03JAN04
CURVE NO.: FR-6140